

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213082  
Address: 4729 NE SARATOGA CT, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Thursday, July 21, 2022

Corrective Action Required:

1	Misc	-Obtain lawn irrigation permit -Deck piers not approved on record **please submit engineer letter for the deck pier -Nail deck joist hangers ; attach deck beam to each post with two 1/2" through bolts or equivalence -Final grade, sod, sump pump extension
---	------	---

**Comments:**