

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213583

Address: 3825 SW WALSH DR, LEES SUMMIT, MO 64082 3823 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, July 21, 2022

Corrective Action Required:

1	Misc	-permanent addresses meter can and disconnects -submit as graded plot plan for review and approval -splash blocks and sump pump discharge to extend 36" from foundation -provide gravel base water meter pit -handrail required at deck stairs -provide landing at deck stair flight
---	------	---

****3823 AND 3825 OK FOR TCO, TCO EXPIRES 7/28/22**

Comments: