

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221405
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Not Ready	Friday, July 22, 2022

Corrective Action Required:

1	Miscellaneous Correction	-Provide collar ties 4' oc max -Support hips to beams -Nail rafters to joists per code
---	--------------------------	--

***7/22/22 CEILING COVERED WITHOUT APPROVAL

Comments: