

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221051
Address: 3218 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Mitchell Schwarz	Failed	Friday, July 22, 2022

Corrective Action Required:

1	Misc	INSPECTION DENIED EROSION CONTROL NOT IN COMPLIANCE. Mitchell Schwarz 07/22/2022 7:58 AM
		install erosion control correct interior drain tile and secure. drain tile is above the plumbing and floor.

Comments: