

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222195
Address: 4712 NE POCONO CIR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Khanh Nguyen	Partial	Friday, July 22, 2022

Corrective Action Required:

1 Misc

Pool bonded:
-perimeter

****Below must be bonded at final: Pool cover framing and rails, equipments,
and pool water**

Comments: