

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20212196
Address: 1630 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Adam Nacke	Partial	Friday, July 22, 2022

Corrective Action Required:

1	Miscellaneous Correction	7-7-22 RH. 3 Sidewalk panels at Hideaway and Stewart were broken at ADA Ramps. 1 sidewalk panel at Hideaway and Overlook was broken at ADA Ramps. We believe that utility companies could of been the ones that damaged these panels. 7-22-22 AN spoke with Doug and Brandon . The ADA ramps will be repair as the houses go in.
---	-----------------------------	---

Comments: