## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20215940

Address: 625 NW EDGEWOOD CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

**Final Building Inspection -** Shawn Hoffman Failed Friday, July 22, 2022

Residential

Corrective Action Required:

2 Misc Electrical whips must be secured 12@ from disconnect

**Comments:**