

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213190  
Address: 1924 SW RIVER RUN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Friday, July 22, 2022

Corrective Action Required:

1 Misc

- Fb back wall of fireplace space complete and used approved methods
- Nail rear dining CSPF wall siding per 1/S4.1. Header min (2)2x12(address engineer letter referring to different area than detail)
- Fb bedroom 4 wall from soffit

**Comments:**