

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210567  
Address: 3053 NW THOREAU LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Failed	Friday, July 22, 2022

Corrective Action Required:

1	Miscellaneous Correction	- Complete plumbing master tub - Provide handrail for steps in retaining wall to fire pit. R311.7.8  no access to inside
---	-----------------------------	---

**Comments:**