

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214290
Address: 1399 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Friday, July 22, 2022

Corrective Action Required:

1	Miscellaneous Correction	-COMPLETE RATED ASSEMBLY AT SEPARATION WALL- SEAL THROUGH PENETRATIONS, PROVIDE STENCLING PER CODE
---	-----------------------------	---

Comments: