

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216043
Address: 1617 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Mitchell Schwarz	Failed	Friday, July 22, 2022

Corrective Action Required:

1	Misc	provide minimum 10 psi at gas gauge for inspection. gauge not working correctly. Mitchell Schwarz 07/22/2022 10:29 AM
---	------	---

Comments: