

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216073  
Address: 520 SE DAVID RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Friday, July 22, 2022

Corrective Action Required:

1	Misc	-secure gas line at fire place -seal penetration for gas line at fire place -address holes in floor joist closer than 2" above wall bar(REPAIR PER ENGINEER LETTER)
---	------	---

**\*\*OK TO INSULATE\*\***

**Comments:**