

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215650  
Address: 2038 SW FARM FIELD LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Friday, July 22, 2022

Corrective Action Required:

1 Misc

- address over notched lvl hip rafter above breakfast area
- address all over notched rafters above living room
- smoke alarm must comply with code section R 314.3
- fireblock top of furr out wall in basement bath
- provide venting for kitchen sink

**Comments:**