

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220013  
Address: 3546 SE CORBIN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Friday, July 22, 2022

Corrective Action Required:

1	Misc	-resolve outstanding inspection fee -submit as graded plot plan for review and approval -final grade and sod -splash blocks -install all cover plates and outlets -install rear deck door hardware -provide landing at deck stairs
---	------	--

**Comments:**