

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216072
Address: 524 SE DAVID RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, July 22, 2022

Corrective Action Required:

1	Misc	-provide (2) 1/2" through bolts at each post/beam connection per code -WSP panel interior and exterior side of wall at great room per plans -osb at interior and exterior of wall at basement den windows per plans (15/32 osb with 8D nails 6" edge 12" field per plans)
---	------	--

****OK TO INSULATE****

Comments: