## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

## Permit #: PRSITE20214153 Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 640812100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
Pavement-Proof Roll		Eric Sharp	Partial	Thursday, July 21, 2022
Informational:				
1	Misc	They had a tandem dump truck with a 20.12 ton load. We proof rolled the chemical stabilization on Black Twig. The sub-grade was solid enough for them to start laying base rock. RP 12-14-21		
Informational:				
2	Misc	They had a tandem dump truck with a 29.59 ton load. We proof rolled the parking lot subgrade. The northern edge was the only area that failed. The were going to rework that section and add some extra rock. RP 12-14-21		
Informational:				
3	Misc	They had a tandem dump truck with a 19.63 ton load. We proof rolled the curb line for both parking lots and Black Twig. A majority of the subgrade was solid. The few areas in question, they will rework the area with additional rock. RP 12-15-21		
Informational:				
4	Misc		truck with a 19.7 ton load. roof roll for laying base asp	-
Informational:				
5	Misc	-	h 20.12 ton load, on parking ig Cir. All areas were solid a	-
		-	n 20.24 ton load on northerr with issue was Far East end	

existing parking lot where a sprinkler had saturated the ground. 7/16/22 ES

ESS cutting grade on south parking lot of apartments. Will do proof roll 7/21 pm. 7/20/22 ES

ESS performed proof roll on stabilized sub base with 19.91 ton load. Passed. 7/21/22 ES

Comments: