



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110161, Building Permit - Commercial
Address: 1170 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Friday, March 11, 2011

Corrective Action Required
6 MISC

CLARIFICATION REQUIRED ON WALL TYPE "4A" DESIGNATED AS
"FIREWALL"

Comments: IF COVER, AT RISK, DUE TO OUTSTANDING QUESTION REGARDING WALL TYPE DESIGNATION ON DRAWINGS.