

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216422  
Address: 3550 SE CORBIN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Monday, July 25, 2022

Corrective Action Required:

1	Misc	-complete sidewalk, sidewalk inspection required -final grade and sod -provide gravel base water meter pit -submit as graded plot plan for review and approval -splash blocks all downspout and sump pump locations, min 36" discharge from foundation -provide landing at deck stairs -(2) 1/2" through bolts each post/beam connection at deck
---	------	--

OK FOR TCO - HOUSE USED AS MODEL

**Comments:**