

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213383  
Address: 3204 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector:       | Outcome: | Date:                 |
|-------------------------------------------------|------------------|----------|-----------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Mitchell Schwarz | Failed   | Monday, July 25, 2022 |

Corrective Action Required:

|   |      |                                                                         |
|---|------|-------------------------------------------------------------------------|
| 1 | Misc | -bottom step at basement stairs over 7 3/4" , check all when corrected. |
|---|------|-------------------------------------------------------------------------|

**Comments:**