

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20213109
Address: 3723 SW WALSH DR, LEES SUMMIT, MO 640823725 SW WALSH DR, LEES SUMMIT, MO 640823727 SW WALSH DR, LEES SUMMIT, MO 640823721 SW WALSH DR, LEES SUMMIT, MO 64082
Inspected On: Monday, July 25, 2022
Inspected By: Patrick Schonfeldt
Expiration Date: 8/24/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Temporary C of O	Monday, July 25, 2022

Corrective Action Required:

1	Misc	**PER BUILDER UNIT 3721 WILL BE MODEL HOME AND NOT 3727
		-Provide permanent address labels at meter cans and disconnect
		-splash blocks, min 36" discharge from foundation
		UNIT 3727: ok for TCO
		UNIT 3721: ok for TCO, this unit is to be used as model
		UNIT 3723: ok for TCO

UNIT 3725: ok for TCO