

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20202637
Address: 1001 SE BAILEY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Monday, July 25, 2022

Corrective Action Required:

1	Misc	Pre final
---	------	-----------

- Provide permanent labels and schedules throughout
- Secure mc at mechanical rooms throughout
- Label plumbing in locker room vestibules and storm at mechanical room
- Exterior and rooftop not inspected
- Secure electrical at mechanical rooms throughout

Area A

- Complete mister (spark arrestor) for dust collection

C:

- C115D- complete shower grab bars

D

- 101 open boxes for shades at perimeter
- 103 open box for shades
- 110A-complete restroom

112-COMplete STAIRS

E

CORRECT RESTROOM GRAB BARS THROUGHOUT

F

101- OPEN BOXES (CAMERAS)

201- Complete BMS, secure condensate lines, secure mc

Comments: