

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212317
Address: 2113 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Eric Sharp	Passed	Monday, July 25, 2022

Informational:

1 Misc Forms were placed and aggregate was present and compacted. They didn't have the required 4 inches, so I had them dig out the low spots. RP 4-4-22

Corrective Action Required:

2 Misc Still needs the sidewalk in front of the house. Need to replace broken panel on the ADA ramp too. RP 4-8-22

Informational:

3 Misc Sidewalk meets LS and ADA spec. 7/25/22 ES

Comments: