



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100231, Building Permit - Commercial
Address: 930 NW BLUE PKWY, Unit:P, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Monday, March 14, 2011

Corrective Action Required
2 MISC

OK TO COVER CEILING GRID AND ABOVE-CEILING SYSTEMS EXCEPT ABOVE THREE HANGING SOFFITS. A/E LETTER REQUIRED CERTIFYING ADEQUACY OF SUPPORT OF HANGING SOFFITS.

Comments: