

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214416
Address: 540 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Engineering	John Jackson	Temporary C of O	Monday, July 25, 2022

Informational:
1 Misc Punch list items for Final Occupancy
1. Vegetation
2. Clean up debris and trash from site.
3. Clean or powerwash sidewalks around site.

Informational:
2 Misc Temorary Occupancy is givien

Needed for Final Occupancy
1. Meter needs to be raised up so it is 14-18 " from grade.

Comments: