



July 25, 2022

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

**RE: Field issue of continuous solid blocking for Lot #113 Manor at Stoney Creek – 4417 SW Grindstone Cir
Lee's Summit, MO 64082 – Permit # PRRES20220089**

- Plans call for continuous solid blocking between floor joists under kitchen island.

Recommended modifications:

- Blocking shall be omitted if HVAC or plumbing lines are in floor joist bays requiring blocking.

Sincerely,

A handwritten signature in blue ink, appearing to read "B. Huxol", is written over a light blue horizontal line.

Bradley Huxol, PE

