

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215284

Address: 3639 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643639 NE AKIN DR, Unit:C, LEES SUMMIT, MO
640643639 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643639 NE AKIN DR, Unit:A,
LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Failed	Tuesday, July 26, 2022

Corrective Action Required:

1 Misc

UNIT C:

-Support plumbing per code above kitchen **support 3" DVW drain @ max 4 ft

UNIT D:

-Fb wall plate penetration by duct at master closet wall

Comments: