

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20213323
Address: 3813 SW WALSH DR, LEES SUMMIT, MO 640823811 SW WALSH DR, LEES SUMMIT, MO 64082
Inspected On: Tuesday, July 26, 2022
Inspected By: Patrick Schonfeldt
Expiration Date: 8/25/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Temporary C of O	Tuesday, July 26, 2022

Corrective Action Required:

1	Misc	-Provide permanent address labels at meter can and disconnect -connect sewer tracer wire to box at grade
---	------	---

UNIT 3811 OK FOR TCO, TCO EXPIRES 7/19/22**

-Sump pump extension, min 36" discharge from foundation

UNIT 3813:

-correct grade south side, negative slope towards foundation
-Sump pump extension

