

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213776
Address: 3113 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, July 26, 2022

Corrective Action Required:

1	Misc	-sod -check water meter at time of final grade and sod -handrail at front stoop as required -guard rail at front stoop as required by code -properly illuminated home address -splash blocks and sump pump discharge to extend 36" from foundation -spark rings at kitchen outlets where required by code -security screws at rear door -set screw sheered off at what're anti syphon device -multiple basement stairs exceeding 7 3/4"
---	------	--

Comments: