

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215300
Address: 500 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Tuesday, July 26, 2022

Corrective Action Required:

1	Misc	-Complete corrections for all other departments -Label RTUs and disconnect -Backflow devices at all hard piped equipment -All drain lines to be 1" above flood level rim -Remove trash from rooftop -Vertical grab bar to be 39-41 aff -Mirror to be 40" to reflective surface -Provide restroom signage -Connect light pole ground to equipment ground
---	------	---

Comments: