


July 26, 2022

Summit Homes 120 SE 30th St Lee's Summit, MO 64082

RE: Revision to patio covering header and front door header Lot #25 Cobey Creek – 520 SE Carter Rd, Lee's Summit, MO 64082 – Permit # PRRES20220422

Recommended modifications:

- Patio covering shall be as shown in image below.
- Extend third ply 2x10 into wall and support with jack stud.



Revision to front door header:

• Front door header was installed underneath top plate and off center.

Recommended modifications:

Install (3) #2 2x10 DFL header above front door transom window opening.

Sincerely,

Bradley Huxol, PE