

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215300
Address: 500 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Water Utilities	Joe San Nicolas	Temporary C of O	Tuesday, July 26, 2022

Corrective Action Required:

1	Miscellaneous Correction	Provide backflow certification results for the domestic water service and irrigation devices.
---	--------------------------	---

Comments: