# CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

# **DEVSERVICES.CITYOFLS.NET**

# **Inspection Summary**

Permit #: PRRES20211291

Address: 2316 SW CHASE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Mitchell Schwarz Failed Wednesday, July 27,

Residential 2022

## Corrective Action Required:

1 Misc

- -erosion control to be maintained until sod in in place
- -obtain lawn irrigation permit
- -sod
- -check water meter at time of sod
- -splash blocks and sump pump discharge to extend 36" from foundation
- -address pending driveway and sidewalk inspections
- -label all non GFCI outlets in unfinished spaces
- -hot neutral reverse in master bath outlet
- -spark ring required above fireplace
- -steps to back patio to be to code step greater than  $7\,3/4"$  , rises greater than
- 3/8" difference
- -identify sewer tracer wire

### **Comments:**