

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215650
Address: 2038 SW FARM FIELD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Wednesday, July 27, 2022

Corrective Action Required:

1	Misc	-address over notched lvl hip rafter above breakfast area -address all over notched rafters above living room -smoke alarm must comply with code section R 314.3 -fireblock top of furr out wall in basement bath
---	------	--

Comments: