

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20213776
Address: 3113 SW ARBORTREE DR, LEES SUMMIT, MO 64082
Inspected On: Wednesday, July 27, 2022
Inspected By: Mitchell Schwarz
Expiration Date: 8/27/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|------------------|-----------------------------|
| Occupancy Inspection - Codes Residential | Mitchell Schwarz | Temporary C of O | Wednesday, July 27, 2022 |

Corrective Action Required:

| | | |
|---|------|-------------------|
| 1 | Misc | TCO UNTIL 8/27/22 |
|---|------|-------------------|

- sod
- check water meter at time of final grade and sod
- splash blocks and sump pump discharge to extend 36" from foundation
- spark rings at kitchen outlets where required by code