

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20213480
Address: 125 NW AMBERSHAM DR, LEES SUMMIT, MO 64081
Inspected On: Wednesday, July 27, 2022
Inspected By: Michael Harkins
Expiration Date: 8/25/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Temporary C of O	Wednesday, July 27, 2022

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | - Final grading and sod
- Splash block
- obtain Irrigation permit and submit back flow certificare
- raise water meter height to grade. |
|---|------|--|

8/25/22 YCO Expiration