

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214077
Address: 3104 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, July 28, 2022

Corrective Action Required:

2	Misc	-splash blocks and sump pump discharge to extend 36" from foundation -provide as graded plot plan -pay all fees -address piers poured without inspection -check water meter at time of sod -Lock out for hot water heater breaker -shower glass in master to be tempered -combo smoke outside basement bedrooms -security screws at basement doors -water anti syphon device in basement with set screw install and sheared off
---	------	--

Comments: