## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20221791

Address: 4717 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Erosion Control Khanh Nguyen Failed Thursday, July 28, 2022

Corrective Action Required:

1 DCM2 ESC DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS

DEFICIENT UNTIL ADEQUATE EROSION CONTROL PROVIDED.

INSTALLATION

Corrective Action Required:

2 Miscellaneous 7-28-22 AN silt fence needs to be installed immediately, street needs to be

Correction cleaned up also curb inlet needs to be cleaned out.

## **Comments:**