

# Straub CONSTRUCTION

Quality Assured Since 1920

12/2/2010	
<b>REQUEST FOR INFORMATION</b>	
RFI NO: 35	
<b>Submitted To:</b>	WSK&F 110 Armour Road North Kansas City, MO 64116
<b>Phone:</b>	816-300-4101
<b>Fax:</b>	816-300-4102
<b>PROJECT:</b> Lee's Summit Firestation #2 2000 NE Rice Road Lee's Summit , MO 64064	
<b>Submitted By:</b> Cory Poulsen Straub Construction	<b>Drawing/Detail No.:</b>  C1.04 C1.03 <b>Specification Section:</b>
<b>Cost Effect:</b>	<b>Distributed To:</b>  Dustin Watkins Stephen Aldridge Rick Poeschl Rick Kuhl
No Cost Effect <input checked="" type="checkbox"/>	
Unknown <input type="checkbox"/>	
<b>Written Description of Problem - Attach Sketches as Required</b>	
<p>The top of the 24" RCP pipe at the North drive will be right under the concrete paving with the bell of the pipe projecting 2-3" into the paving.</p> <p>Per a phone conversation 12-2-10 with Lance at CFS this is acceptable</p>	
<b>Response Time:</b>	
<b>Please Reply by:</b> As soon as possible	
<b>Contractor's Proposed solution:</b>	
<b>Architects Proposed Solution:</b>  THIS IS ACCEPTABLE	
<b>Approval Date:</b>	<b>Disapproved Date:</b>
DUSTIN 12/3/10	
Straub Construction Company, Inc. 7775 Meadow View Drive Shawnee KS 66227	