

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220630  
Address: 1249 NE GOSHEN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Adam Nacke	Failed	Thursday, July 28, 2022

Corrective Action Required:

1	Miscellaneous Correction	7-28-22 AN silt fence need to be installed and curb inlet needs to be cleaned out
---	-----------------------------	---

**Comments:**