

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215940  
Address: 625 NW EDGEWOOD CT, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Residential</b>	Khanh Nguyen	Failed	Thursday, July 28, 2022

Corrective Action Required:

1	Misc	-Provide gfci breaker protection for pool pump
---	------	--

**Comments:**