

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

July 28, 2022

CLAYTON PROPERTIES GROUP, INC
120 SE 30TH ST
LEES SUMMIT, MO 64082

Permit No: PRSGN20223571
Project Title: 499 SE 150 Hwy monument sign
Project Address: 499 SE M 150 HWY, LEES SUMMIT, MO 64082
Parcel Number: 70500040401000000
Location / Legal Description: SEC-29 TWP-47 RNG-31---PT SE 1/4 DAF: BEG NE COR COBEY CREEK 1ST PLAT TRACT H TH N 87 DEG 44 MIN 49 DEG 05 MIN 50 SEC E 35.36' TH ALG CURV LF ITB N 02 DEG 10 MIN 54 SEC E RAD 175' DIST 115.48' TH ALG 87 DEG 54 MIN 10 SEC W 27.55' TH N 02 DEG 05 MIN 50 SEC E 50' TH S 87 DEG 54 MIN 10 SEC E 27.55' TH TH N 87 DEG 54 MIN 10 SEC W 29' TH N 02 DEG 05 MIN 50 SEC E 55' TH S 87 DEG 54 MIN 10 SEC E 24' TH N
Type of Work: Sign
Occupancy Group: NOT APPLICABLE
Description: Cobey Creek monument sign

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Sign Permit Review

Reviewed By: Shannon McGuire

Rejected

1. The proposed monument signs are oversized per UDO standards. Monument signs for residential uses in the PMIX zoning district are limited to a maximum of 32 sq. ft. sign area; 72 sq. ft. structure area. The height is limited to 6 feet. Staff cannot administratively approve the signs as submitted. Under separate application, the Planning Commission may consider sign applications for permitted permanent sign types which exceed the maximum number of signs permitted, maximum sign area, or maximum height.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.