

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216144
Address: 1920 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Friday, July 29, 2022

Corrective Action Required:

1	Misc	-FINAL DRIVEWAY AND SIDEWALK INSPECTIONS REQUIRED, CONTACT DEVELOPMENT SERVICES TO SCHEDULE -FINAL GRADE AND SOD -SPLASH BLOCKS -MAX 3/8" VARIANCE BETWEEN STAIRS RISES, SEE GARAGE STAIRS, IRC R311.7.5.1 -JACUZZI TUB MOTOR ACCESS REQUIRED, SEE IRC P2720.1
---	------	--

Comments: