

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211291  
Address: 2316 SW CHASE CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mark Harding	Failed	Friday, July 29, 2022

Corrective Action Required:

1	Misc	-sod -check water meter at time of sod -splash blocks and sump pump discharge to extend 36" from foundation
---	------	---

**Comments:**