

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220635
Address: 1916 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, July 29, 2022

Corrective Action Required:

1	Misc	-Install collar ties near roof ridge above garage -Fb garage duct chase from soffit; -Install roof flashing at dryer duct roof penetration -Provide min 12"x12" of clear access opening to hydro tub pump. -Provide purlin support every 4 ft or less -Over notched joist below half bathroom
---	------	--

****OK TO INSULATE**

Comments: