

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216103
Address: 2023 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Friday, July 29, 2022

Corrective Action Required:

1 Misc

-address garage portal frame not framed to plans
add 2x4 over the bottom of LVL and studs along the face of the header. nail 3" o.c. to header and each stud.

Replace through bolts to the faace of the dbl rim at the deck.
ok to insulate and recall when header issue is complete.

Comments: