

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216279
Address: 113 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Monday, August 01, 2022

Corrective Action Required:

1	Miscellaneous Correction	provide anchor bolt at plate break garage near stairs Nail PFH portal frame 2x4 to LVL 2 rows @3" on center Nail corner exterior wall office at garage top Nail exterior corner dining room north east top Fire block RA pipe penetration hall way at foyer Complete Timbers on front porch Fire block end of soffit bottom of stairs Fire block top of chase basement family room and bedroom 3 Fire block end of soffit vertical to horizontal at chase basement family room near arch
---	--------------------------	--

Comments: