

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20221062

Address: 904 NW PRYOR RD, LEES SUMMIT, MO 64081908 NW PRYOR RD, LEES SUMMIT, MO 64081900 NW  
PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Stabilized Subgrade</b>	Eric Sharp	Passed	Monday, August 01, 2022

Informational:

1 Misc

ESS has a dirt crew on site working on compacting site and putting Tensar TriAx TX5 geogrid with aggregate down. 6/6/22 ES

ESS working on grading and compacting aggregate for sub base. 6/7/22 ES

Spoke with Cody this morning. They plan on doing a proof roll on Tuesday morning weather permitting. 6/8/22 ES

ESS working on rolling/grading and staking. 6/13/22 ES

ESS performed a proof roll on curb sections today using a truck with 20.05 ton load. All areas passed. 6/15/22 ES

ESS performed a proof roll for putting down base asphalt using a truck with a 20 ton load. All areas passed. 6/30/22 ES

Parking lot completed. 8/1/22 ES

**Comments:**

