

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20211246

Address: 1010 NW PRYOR RD, LEES SUMMIT, MO 640811000 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Camera Test	Eric Sharp	Passed	Monday, August 01, 2022

Informational:

1 Misc

Email sent to water to get this section camera'd. 6/7/22 ES

Water was onsite working on bond inspection. 6/17/22 ES

Spoke with Matt, water approved of Sanitary Sewers. 8/1/22 ES

Comments: