

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220570
Address: 1120 NW MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|-------------------------|
| Footing Inspection - Commercial | Robb Popp | Partial | Monday, August 01, 2022 |

Informational:
1 Misc

EXTERIOR GRADE BEAM AND PAD:
LINE T: 1-10; LINE 10: T-P

INTERIOR COLUMN PADS-OK TO POUR:
-LINE 2: K TO S
-LINE 3: L TO S
-LINE 4: L TO S
-LINE 5: M TO S
-LINE 6: M TO S
-LINE 7: M TO S
-LINE 8: N TO S
-LINE 9: N TO S

Comments: