CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20215409 Address: 940 NW PRYOR RD, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Occupancy Inspection - Codes Commercial		Inspector:	Outcome: Failed	Date: Monday, August 01, 2022
		Robb Popp		
Corrective	e Action Required:			
1	Miscellaneous Correction	-Upload Health Department report to portal -Provide certification that fireproofing is installed per instructions and to proper thickness-obtain letter and upload to portal -Provide screening at CO2 tank at exterior to conceal tank -Seal all through floor penetrations (floor sinks & floor drains) with approved material-per UL1479 and ASTM E84 -Label panel, complete panel schedule -Provide plumbing protection at sink per IPC 404.3		
Informatio	onal:			
2	Misc	Development Ordinance, building shall be fully scr using either of the follow	REENING. To meet the requi , the CO2 container housed o eened from view up the hei ving screening options: 1) ma ng); or 2) evergreen shrubs.	on the exterior of the ght of said container

Comments: